IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for Carson City

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During August 2022, we did not complete all monitoring or testing for total coliform bacteria, and therefore cannot be sure of the quality of your drinking water during that time.

What happened? What is being done?

We took our required monthly routine bacteriological samples on August 24, 2022. We were notified that one sample was total coliform positive on August 26, 2022. Within 24 hours, we are required to collect at least one groundwater source sample from each groundwater source in use at the time the total coliform positive sample was collected. However, we inadvertently missed monitoring our groundwater source within 24 hours. We returned to compliance on August 29, 2022, when we collected the required ground water source samples. All samples taken on August 29, 2022, were negative for total coliform bacteria. We are making efforts to ensure this does not happen again.

What should I do?

There is nothing you need to do at this time. This is not an emergency. You do not need to boil water or use an alternative source of water at this time. The results of the sample were negative for bacteria. Even though public health was not impacted, as our customers, you have a right to know what happened and what we did to correct the situation.

For more information, please contact:	789-589-5515
Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.	
This notice is being sent to you by Carson City.	
CERTIFICATION:	WSSN: 01170
I certify that this water supply has fully complied with Safe Drinking Water Act, 1976 PA 399, as amended	and the administrative rules.
Signature: Title: Public C	LORKS DIRECTORED Distributed: 8/7/23